

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/ MDB /JULY/ 95

Dated: 09/07/2026

It is certified that an inspection team headed by Raman Kumar Jha Lab. Asst. (Name of Officers with designation) from PHED Madhubani

inspected the DAV PUBLIC SCHOOL MADHEPUR DIST- MADHUBANI (BIHAR) PIN 847408.
(Name & Address of the school) on 08-07-2026 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no LAB/JULY/95 dated 09/07/2026 of Madhubani (PHED Lab) certified that the DAV PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till JANUARY 2026.

Signature with Seal:
Name ASRAF NAJMI

Designation : CHEMIST
Name & Address of the Office / Department : P. H. E
.D MADHUBANI.....

TO,
THE PRINCIPAL
DAV PUBLIC SCHOOL MADHEPUR
DIST- MADHUBANI (BIHAR) PIN
847408.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

P.H.DIVISION, MADHUBANI

LT No - 95 Date - 09.07.26
Sample Collected & Submitted BY RAMAN JHA LAB STAFF MADHUBANI.

Sampling Date:- 08/07/2026

Testing Date:- 09/07/2026

Months:- JULY 2026

SI No	Block	Panchayat	Village	Source of Water	Name of Location/ Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	TDS	EC	Bact.	Remarks
1	MADHEPURA	MADHEPURA	LAXMIPUR CHOWK	R/O	DAV PUBLIC SCHOOL	7.1	1.5	100	196	16	5	40	0.26	0.2	77	132	A	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.1 - 1.5	500 - 2000		Present/Absent	

*BDL- Below Detection Limit

*A - Absent

NOTE:- THIS TEST REPORT IS VALID FOR SIX MONTH FROM THE DATE OF TESTING.

Raman Jha
09/07/2026
Lab Assistant

District Level Laboratory, Madhubani

M. D. Wi
09/07/26
Chemist

District Level Laboratory, Madhubani

